



Fire Test Results - Escenta

American Fire Test Results

Test carried out in accordance to ASTM E84 "Standard Test Method for Surface Burning Characteristics of Building Materials" by an accredited external laboratory.

Flame Spread Index	5
Smoke Developed Index	5
Flame Spread Classification	Class A

ST0108(1)

Armourcoat Limited
Morewood Close London Road
Sevenoaks Kent TN13 2HU United Kingdom
Tel: +44 (0)1732 460 668 Fax +44 (0)1732 450 930
Email: technical@armourcolor.co.uk

web: www.armourcolor.com